

C

Asbestos Register

Location:

Date:

Location	Product type	Extent	Accessibility	Condition	Surface treatment	Asbestos type	Sample No.	Sampled/ Presumed strongly presumed	Material Risk Score	Priority Risk Score	Total risk score
Stairs	Floor tiles	24 m ²	good	good	Sealed in matrix	Chrysotile	1	sampled	2	8	10

Material Scores above 10 have a high potential to release fibres

Determine a recommended course of action based on the scoring above

Sample No.	Action	Time frame	Works by whom?
Sample 1			
Sample 2			
Sample 3			
Sample 4			